



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Co.

Ref.: ADDC/LVSGC/AAK/117/11

Date: 03 NOV 2011

**To: M/s Gulf Dynamic Switchgear Co. LTD.
P.O.Box 6155
Sharjah, U.A.E.
Tel No: 065338568
Fax No: 065336383**

Subject: Approval of LV Switchgear Materials

Greetings,

We refer to your letter dated 13/9/2011 for the proposed LV materials. ADDC has reviewed the submittal and please be informed that the proposed LV materials, as detailed below, **is approved by ADDC LV Switchgear Committee** and included in the List of Vendors for the prospective Supplier of the LV Switchgear in the Emirate of Abu Dhabi.

Sl. No	Product Reference	Maximum Rating/ Cross section	certificate	Manufacturer/ Country of Origin
1.	3200A PANEL, FORM 4	3200A 2x120x10	ASTA 18289	Gulf Dynamic switchgear Co. Ltd./UAE
2.	1600A PANEL, FORM 4	1600A 2x60x10	ASTA 18288	
3.	400A FORM II PANEL (ESTENDABLE UPTO 10 WAY)	400A 1x30x10	ASTA 18277	
4.	250A FORM II PANEL (ESTENDABLE UPTO 8 WAY)	250A 1x20x10	ASTA 18276	

1. This approval is valid for **3 year** of date of this letter.
2. The above approval does not relieve the Contractors in complying with RSB guidelines and ADDC standards that are applied to the LV Switchgear and Panel Boards.
3. All the breakers (both the incoming and outgoing) shall be restricted to the components used in the test or to be tested by any of the approved certified authorities.
4. Submission of certificate of conformity for every switchgear assembly, at every delivery.
5. Provision of the performance data of the switchgear from the owners of the installation for a period of 3 years.

1/2





شركة أبوظبي للتوزيع
Abu Dhabi Distribution Co.

Ref.: ADDC/LVSGC/AAK/117/11

Date: 03 NOV 2011

6. Any malfunction or repeated faults during this period may lead to the cancellation of the ADDC approval.
7. It is the responsibility of the manufacturer to comply with any updated IEC standards that would be released during these period by means of additional test as required.
8. It is the responsibility of the supplier to keep their customer aware of the special conditions stated in the test reports that restrict the use of the approved material at different connection environment.
9. The company should be registered in ADWEA Vendor list (www.adwea.ae).

Regards,




Engr. ALI AL MENEHALI
Chairman, LV Switchgear Committee

